

ANTIVIRAL AIR CLEANER BY EES

MODEL	AAC-8	AAC-18	AAC-32	AAC-50	AAC-59	AAC-72	AAC-98
AIR FLOW (ACFM)	2,500	5,000	10,000	14,000	17,000	20,000	30,000
A	7'-8"	8'-10"	10'-1"	11'-3"	11'-3"	12'-5"	13'-8"
B	9'-5"	9'-5"	9'-5"	9'-5"	9'-5"	9'-5"	9'-5"
C	3'-11"	4'-5"	5'-2"	5'-9"	5'-9"	6'-4"	7'-1"
D	8'-9"	8'-9"	8'-9"	8'-9"	8'-9"	8'-9"	8'-9"
H	8'-1"	9'-2"	10'-3"	11'-5"	12'-6"	12'-6"	13'-8"
INLET/OUTLET, F x G	18"x30"	32"x36"	48"x48"	60"x60"	60"x72"	72"x72"	84"x84"
CURRENT (MA)	50	100	200	250	300	350	500
VOLTAGE (KV)	60	60	60	60	60	60	60
PLASMA POWER (KW)	3	6	12	15	18	21	30
WASH WATER (GPM)	12	24	45	70	82	100	150
TOTAL CONNECTED POWER (KW)	8	11	17	20	23	26	35
WEIGHT (LBS)	1900	2700	3000	3200	3600	3900	4500

NOTES.

1. INDOOR OR OUTDOOR LOCATION.
2. OPERATING TEMPERATURE FROM 40 TO 140 DEG. F.
3. LINE VOLTAGE: 380 VAC, 400 VAC, 415 VAC, 480 VAC.
4. DESIGN MAX. OPERATING PRESSURE: 20 IN. W.C.
5. ALL DIMENSIONS AND WEIGHT ARE APPROXIMATE.
6. INLET AND OUTLET DUCTS BY OTHERS.
7. SUPPORT FRAME AND LOAD DISTRIBUTION BY OTHERS.
8. UNIT TO BE CONNECTED TO FACILITY GROUND WITH LINE RESISTANCE NO LESS THEN 4 OHMS.
9. WASH WATER DRAINS TO BE CONNECTED TO FACILITY SEWER SYSTEM.